



# Lehigh Acres Fire Control & Rescue District

## Life Safety Management Division

Life Safety Division  
636 Thomas Sherwin Ave S  
Lehigh Acres, FL 33974

Phone (239) 303-5300  
Fax (239) 369-2436

### FIRE INSPECTION REPORT

**Business Name:** Donna J Brasley Technical Academy **Contractor:** \_\_\_\_\_

**Address:** 60 Bell Blvd, Unit B **Permit:** \_\_\_\_\_

**Date:** 7/18/18 **Time:** 0900 **Occupant/Tenant/Owner:** \_\_\_\_\_

**Business Phone:** \_\_\_\_\_ **Occupant/Tenant/Owner Phone:** \_\_\_\_\_

SATISFACTORY INSPECTION  FAILED INSPECTION – NOTICE OF VIOLATION

- 1) Provide placard for FALGGA - 60-0081 for wood frame, light-weight roof structural components, on west wall of building, visible as emergency vehicles approach.
- 2) Repair defective exit sign over east exit door. NFPA 101-4.5.8
- 3) Electrical strip plugs shall not be interconnected to each other.  
NFPA 1-11.1.4 - Mitigated at time of inspection:

*Note: This inspection only provided for single building. Any other buildings on site are under exclusive management and use of church.*

Violation(s) # 2. Must be corrected NOT LATER THAN 30 Days.

Violations requiring reinspections will be charged reinspection fees. Page \_\_\_\_\_ of \_\_\_\_\_

Received By: [Signature]  
(Signature)

Inspector: Ken Bennett

Received By: Joe Torregrosso  
(Print Name)

- Annual Inspection
- Construction Inspection
- Complaint
- Reinspection
- Change of Tenant
- Change of Occupancy
- Other \_\_\_\_\_

Note: The Lehigh Acres Fire Control and Rescue District utilizes the Florida Fire Prevention Code as the base Code, pursuant to the provisions of Florida Statute 633.202. It is available for viewing on-line by visiting NFPA.org and selecting Free Access or logging in with your credentials.  
E-Mail Addresses: Inspector Cooley Fred.Cooley@Lehighfd.com; Fire Marshal Bennett KenB@Lehighfd.com; Administrative Assistant Williams JanisW@Lehighfd.com